



TTI ENVIRONMENTAL, INC.
Consulting & Contracting

1253 North Church Street, Moorestown, NJ 08057
www.ttienv.com o 856-840-8800 f 856-840-8815

May 9, 2022

Sent via email to: knelson@sptsd.org

Mr. Keith Nelson
Somers Point School District
121 W New York Ave
Somers Point, NJ 08244

Re: Lead in Water Testing ESCNJ #19/20-31
Somers Point School District
TTI Project No: 21-359

Dear Mr. Keith Nelson;

Thank you for selecting TTI Environmental, Inc. (TTI) for your environmental needs. This correspondence is being forwarded to report the results of the Lead in Water Testing conducted for your district.

1.0 INTRODUCTION

TTI followed the recommended practices outlined in the Environmental Protection Agency (EPA) 3 T's for Reducing Lead in Drinking Water October 2006, New Jersey Department of Environmental Protection (NJDEP) Division of Water Supply & Geoscience – Lead in Drinking Water: Guidance for Schools & Child Care Facilities. The protocol, which consists of an established sample size volume and water retention time, is designed to identify lead problems at outlets and upstream plumbing within school facilities, and in the water entering the facility.

The initial sampling was conducted on February 2 & 4, 2022, and samples were collected from bubblers, fountains, and other outlets used for consumption and were all first-draw samples (i.e., the stagnant water is sampled before any use occurs).

2.0 SUMMARY

The results of the initial sampling revealed that the sampling point(s) listed below had elevated sources above the standard as set forth in NJAC 6A:26-1.2 and 12.4 of 15 parts per billion (ppb). The following fixture(s) were immediately removed from service:

- **Jordan Road School - 15 / JRS-112-S4 / HomeEc 112 / Sink; 17 / JRS-112-S6 / HomeEc 112 / Sink; 19 / JRS-112-S8 / HomeEc 112 / Sink; 38A / JRS-WKRM-ORS / Room 117 Faculty Work Room / Sink; 50 / JRS-244-SB6 / 244 Faculty Lounge / Sink bubbler.**



Based on information provided by the client, the above points were permanently taken out of service or labeled as being for non-potable use only.

The following attachments are provided for your review:

- Attachment 1 - Sampling Data and Analytical Results (Initial Sampling Event)
- Attachment 2 - Excel Spreadsheet of Analytical Results (Initial Sampling Event)

If you should have any questions or require additional information, please feel free to contact me directly.

Sincerely,
TTI ENVIRONMENTAL, INC.

A handwritten signature in blue ink, appearing to read "Tim Popp".

Timothy Popp
Vice President of Consulting



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Nathanael Roberts
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057**

2/15/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/2/2022. The results are tabulated on the attached data pages for the following client designated project:

21-359 / Jordan Road School

The reference number for these samples is EMSL Order #012201606. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 1 / JRS-GYM-DW1 / Boys Gym **Collected:** 2/2/2022 5:48:00 AM **Lab ID:** 012201606-0001

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 9.67 | 1.00 µg/L | 2/2/2022 KB | 2/3/2022 21:36 JW |

Client Sample Description 2 / JRS-GYM-DW2 / Girls Gym **Collected:** 2/2/2022 5:49:00 AM **Lab ID:** 012201606-0002

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.22 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:03 KB |

Client Sample Description 11 / JRS-HWE-DW3 / Hallway East (Near 106) **Collected:** 2/2/2022 5:53:00 AM **Lab ID:** 012201606-0003

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:08 KB |

Client Sample Description 12 / JRS-HWE-DW4 / Hallway East (Near 106) **Collected:** 2/2/2022 5:54:00 AM **Lab ID:** 012201606-0004

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:09 KB |

Client Sample Description 13 / JRS-HWE-DW5 / Hallway East (Near 106) **Collected:** 2/2/2022 5:55:00 AM **Lab ID:** 012201606-0005

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:11 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 14 / JRS-106-S3 / 106 **Collected:** 2/2/2022 5:56:00 AM **Lab ID:** 012201606-0006

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 1.17 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:12 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 15 / JRS-112-S4 / HomeEc 112 **Collected:** 2/2/2022 6:00:00 AM **Lab ID:** 012201606-0007

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 19.7 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:14 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 16 / JRS-112-S5 / HomeEc 112 **Collected:** 2/2/2022 6:01:00 AM **Lab ID:** 012201606-0008

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 2.99 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:19 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 17 / JRS-112-S6 / HomeEc 112 **Collected:** 2/2/2022 6:02:00 AM **Lab ID:** 012201606-0009

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 42.4 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:20 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 18 / JRS-112-S7 / HomeEc 112 **Collected:** 2/2/2022 6:03:00 AM **Lab ID:** 012201606-0010

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 8.00 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:22 KB |
|-------|------|------|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 19 / JRS-112-S8 / HomeEc 112 **Collected:** 2/2/2022 6:04:00 AM **Lab ID:** 012201606-0011

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 58.2 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:23 KB |

Client Sample Description 20 / JRS-122-S9 / 122 **Collected:** 2/2/2022 6:00:00 AM **Lab ID:** 012201606-0012

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 5.84 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:25 KB |

Client Sample Description 21 / JRS-HWN-DW6 / Hallway North (Near 124A) **Collected:** 2/2/2022 6:13:00 AM **Lab ID:** 012201606-0013

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:29 KB |

Client Sample Description 22 / JRS-HWN-DW7 / Hallway North (Near 124A) **Collected:** 2/2/2022 6:11:00 AM **Lab ID:** 012201606-0014

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:31 KB |

Client Sample Description 23 / JRS-115-S10 / Teacher's Lounge **Collected:** 2/2/2022 5:40:00 AM **Lab ID:** 012201606-0015

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 4.04 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:33 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 24 / JRS-HWS-DW8 / Hallway South (Near Gym) **Collected:** 2/2/2022 5:34:00 AM **Lab ID:** 012201606-0016

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:37 KB |

Client Sample Description 25 / JRS-HWS-DW9 / Hallway South (Near Gym) **Collected:** 2/2/2022 5:33:00 AM **Lab ID:** 012201606-0017

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:39 KB |

Client Sample Description 26 / JRS-HWS-DW10 / Hallway South (Near Gym) **Collected:** 2/2/2022 5:32:00 AM **Lab ID:** 012201606-0018

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:40 KB |

Client Sample Description 27 / JRS-KIT-ICE1 / Kitchen **Collected:** 2/2/2022 5:24:00 AM **Lab ID:** 012201606-0019

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 3.25 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:42 KB |

Client Sample Description 28 / JRS-KITS11 / Kitchen **Collected:** 2/2/2022 5:24:00 AM **Lab ID:** 012201606-0020

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.05 | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:43 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201606

CustomerID: TTIE54

CustomerPO: 034248

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 29 / JRS-KITS12 / Kitchen **Collected:** 2/2/2022 5:25:00 AM **Lab ID:** 012201606-0021

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 22:45 KB |

Client Sample Description 30 / JRS-KITS13 / Kitchen **Collected:** 2/2/2022 5:26:00 AM **Lab ID:** 012201606-0022

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:28 KB |

Client Sample Description 31 / JRS-KITS14 / Kitchen **Collected:** 2/2/2022 5:27:00 AM **Lab ID:** 012201606-0023

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:35 KB |

Client Sample Description 33 / JRS-NRS-S16 / Nurse **Collected:** 2/2/2022 6:23:00 AM **Lab ID:** 012201606-0024

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 10.5 | 1.00 µg/L | 2/2/2022 KB | 2/3/2022 21:38 JW |

Client Sample Description 35 / JRS-HWW-DW11 / Hallway West **Collected:** 2/2/2022 6:16:00 AM **Lab ID:** 012201606-0025

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:37 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201606

CustomerID: TTIE54

CustomerPO: 034248

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 37 / JRS-120-SB1 / 129 **Collected:** 2/2/2022 6:15:00 AM **Lab ID:** 012201606-0026

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 11.5 | 1.00 µg/L | 2/2/2022 KB | 2/3/2022 21:41 JW |

Client Sample Description 38A / JRS-WKRM-ORS / Room 117 Faculty Work Room **Collected:** 2/2/2022 5:40:00 AM **Lab ID:** 012201606-0027

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 48.7 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:39 KB |

Client Sample Description 39 / JRS-PHW-DW12 / Prim Hall West **Collected:** 2/2/2022 6:32:00 AM **Lab ID:** 012201606-0028

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.74 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:40 KB |

Client Sample Description 40 / JRS-PHW-DW13 / Prim Hall West **Collected:** 2/2/2022 6:32:00 AM **Lab ID:** 012201606-0029

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:42 KB |

Client Sample Description 42 / JRS-209-SB2 / 209 **Collected:** 2/2/2022 6:36:00 AM **Lab ID:** 012201606-0030

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 4.18 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:43 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 44 / JRS-211-SB3 / 211 **Collected:** 2/2/2022 6:37:00 AM **Lab ID:** 012201606-0031

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.04 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:45 KB |

Client Sample Description 46 / JRS-212-SB4 / 212 **Collected:** 2/2/2022 6:35:00 AM **Lab ID:** 012201606-0032

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 5.09 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:46 KB |

Client Sample Description 48 / JRS-205-SB5 / 205 **Collected:** 2/2/2022 6:38:00 AM **Lab ID:** 012201606-0033

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 5.87 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:48 KB |

Client Sample Description 50 / JRS-244-SB6 / 244 Faculty Lounge **Collected:** 2/2/2022 6:41:00 AM **Lab ID:** 012201606-0034

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 20.8 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:49 KB |

Client Sample Description 52 / JRS-204-SB7 / 204 **Collected:** 2/2/2022 6:42:00 AM **Lab ID:** 012201606-0035

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 6.24 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:57 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 54 / JRS-203-SB8 / 203 **Collected:** 2/2/2022 6:39:00 AM **Lab ID:** 012201606-0036

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.23 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 21:59 KB |

Client Sample Description 56 / JRS-201-SB9 / 201 **Collected:** 2/2/2022 6:46:00 AM **Lab ID:** 012201606-0037

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 3.45 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:00 KB |

Client Sample Description 58 / JRS-202-SB10 / 202 **Collected:** 2/2/2022 6:43:00 AM **Lab ID:** 012201606-0038

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.30 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:02 KB |

Client Sample Description 60 / JRS-200-SB11 / 200 **Collected:** 2/2/2022 6:45:00 AM **Lab ID:** 012201606-0039

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 4.03 | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:03 KB |

Client Sample Description 24B / JRS-HWS-DW8-BF / Hallway South (Near Gym) **Collected:** 2/2/2022 5:36:00 AM **Lab ID:** 012201606-0040

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:05 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201606
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:30 AM

Project: 21-359 / Jordan Road School

Analytical Results

Client Sample Description 11B / JRS-HWE-DW3-BF / Hallway East (Near 106) **Collected:** 2/2/2022 **Lab ID:** 012201606-0041
 5:51:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:06 KB |

Client Sample Description 21B / JRS-HWN-DW68-BF / Hallway North (Near 124A) **Collected:** 2/2/2022 **Lab ID:** 012201606-0042
 6:09:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:08 KB |

Client Sample Description 35B / JRS-HWW-DW11-BF / Hallway West (Near Nurse) **Collected:** 2/2/2022 **Lab ID:** 012201606-0043
 6:16:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/9/2022 KB | 2/9/2022 22:13 KB |

Client Sample Description 40B / JRS-PHW-DW13-BF / Prim Hall West **Collected:** 2/2/2022 **Lab ID:** 012201606-0044
 6:29:00 AM

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/8/2022 18:23 KB |

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

2/11/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/2/2022. The results are tabulated on the attached data pages for the following client designated project:

21-359 / New York Ave School

The reference number for these samples is EMSL Order #012201647. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, National Organics Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201647
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:15 AM

Project: 21-359 / New York Ave School

Analytical Results

Client Sample Description 1 / NYA-GF-DW1 / Ground Floor **Collected:** 2/2/2022 6:59:00 AM **Lab ID:** 012201647-0001

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:28 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 2 / NYA-GF-DW2 / Ground Floor **Collected:** 2/2/2022 7:01:00 AM **Lab ID:** 012201647-0002

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:29 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 8 / NYA-FF-DW3 / 1st Floor **Collected:** 2/2/2022 7:09:00 AM **Lab ID:** 012201647-0003

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:31 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 9 / NYA-FF-SLS / 1st Floor **Collected:** 2/2/2022 7:13:00 AM **Lab ID:** 012201647-0004

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 3.34 | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:32 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 10 / NYA-FF-NRS / 1st Floor **Collected:** 2/2/2022 7:12:00 AM **Lab ID:** 012201647-0005

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 13.5 | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:34 KB |
|-------|------|------|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201647
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/2/2022 09:15 AM

Project: 21-359 / New York Ave School

Analytical Results

Client Sample Description 11 / NYA-SF-DW4 / 2nd Floor **Collected:** 2/2/2022 7:15:00 AM **Lab ID:** 012201647-0006

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 2.42 | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:38 KB |

Client Sample Description 2B / NYA-GF-DW2-BF / Ground Floor **Collected:** 2/2/2022 7:03:00 AM **Lab ID:** 012201647-0007

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:40 KB |

Client Sample Description 8B / NYA-FF-DW3-BF / 1st Floor **Collected:** 2/2/2022 7:07:00 AM **Lab ID:** 012201647-0008

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:45 KB |

Client Sample Description 12 / Field Blank **Collected:** 2/2/2022 **Lab ID:** 012201647-0009

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/3/2022 KB | 2/4/2022 10:46 KB |

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Nathanael Roberts
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057**

2/18/2022

Phone: (856) 840-8800
Fax: (856) 840-8815

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/4/2022. The results are tabulated on the attached data pages for the following client designated project:

21-359 / Dawes Ave School

The reference number for these samples is EMSL Order #012201786. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 1 / DWS-1FL-GYM-DW1 / Gym, Right **Collected:** 2/4/2022 6:13:00 AM **Lab ID:** 012201786-0001

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:44 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 3 / DWS-1FL-KIT-S1 / Kitchen **Collected:** 2/4/2022 6:17:00 AM **Lab ID:** 012201786-0002

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 3.26 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:52 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 4 / DWS-1FL-KIT-S2 / Kitchen Small **Collected:** 2/4/2022 6:17:00 AM **Lab ID:** 012201786-0003

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 2.60 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:54 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 5 / DWS-1FL-KIT-S3 / Kitchen Deep **Collected:** 2/4/2022 6:17:00 AM **Lab ID:** 012201786-0004

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 3.29 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:55 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 6 / DWS-1FL-PEO-S4 / PE Office **Collected:** 2/4/2022 6:20:00 AM **Lab ID:** 012201786-0005

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 3.53 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:57 KB |
|-------|------|------|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 7 / DWS-1FL-NRS-S5 / Nurse's Office **Collected:** 2/4/2022 6:22:00 AM **Lab ID:** 012201786-0006

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 1.88 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 04:58 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 8 / DWS-1FL-WRK-S6 / Faculty Work Room **Collected:** 2/4/2022 6:25:00 AM **Lab ID:** 012201786-0007

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 15.3 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:00 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 9 / DWS-1FL-MOB-DW3 / Main Office **Collected:** 2/4/2022 6:25:00 AM **Lab ID:** 012201786-0008

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:01 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 10 / DWS-1FL-LIB-S7 / Workroom-Library-100A **Collected:** 2/4/2022 6:27:00 AM **Lab ID:** 012201786-0009

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:03 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 11 / DWS-2FL-203-SB1 / 203 **Collected:** 2/4/2022 6:26:00 AM **Lab ID:** 012201786-0010

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 4.08 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:04 KB |
|-------|------|------|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 12 / DWS-2FL-204-SB2 / 204 **Collected:** 2/4/2022 6:28:00 AM **Lab ID:** 012201786-0011

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:09 KB |

Client Sample Description 13 / DWS-2FL-205A-SB3 / 205A **Collected:** 2/4/2022 6:30:00 AM **Lab ID:** 012201786-0012

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.88 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 20:37 JW |

Client Sample Description 14 / DWS-2FL-206-SB4 / 206 **Collected:** 2/4/2022 6:30:00 AM **Lab ID:** 012201786-0013

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:14 KB |

Client Sample Description 15 / DWS-2FL-205B-SB5 / 205B **Collected:** 2/4/2022 6:30:00 AM **Lab ID:** 012201786-0014

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.55 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:15 KB |

Client Sample Description 16 / DWS-2FL-207-SB6 / 207 **Collected:** 2/4/2022 6:31:00 AM **Lab ID:** 012201786-0015

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:17 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 17 / DWS-2FL-208-SB7 / 208 **Collected:** 2/4/2022 6:32:00 AM **Lab ID:** 012201786-0016

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:19 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 18 / DWS-1FL-101-SB8 / 101 **Collected:** 2/4/2022 6:33:00 AM **Lab ID:** 012201786-0017

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:20 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 21 / DWS-1FL-HW-DW6 / 1st Floor Hall Right **Collected:** 2/4/2022 6:35:00 AM **Lab ID:** 012201786-0018

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:22 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 23 / DWS-2FL-HW-DW8 / 2nd Floor Hall Center **Collected:** 2/4/2022 6:36:00 AM **Lab ID:** 012201786-0019

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:23 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 25 / DWS-1FL-103-SB9 / 103 **Collected:** 2/4/2022 6:36:00 AM **Lab ID:** 012201786-0020

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:28 KB |
|-------|------|----|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 26 / DWS-2FL-210-SB10 / 210 **Collected:** 2/4/2022 6:37:00 AM **Lab ID:** 012201786-0021

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:29 KB |

Client Sample Description 27 / DWS-1FL-102-SB11 / 102 **Collected:** 2/4/2022 6:38:00 AM **Lab ID:** 012201786-0022

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:36 KB |

Client Sample Description 28 / DWS-2FL-209-SB12 / 209 **Collected:** 2/4/2022 6:40:00 AM **Lab ID:** 012201786-0023

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:40 KB |

Client Sample Description 29 / DWS-1FL-104-SB13 / 104 **Collected:** 2/4/2022 6:41:00 AM **Lab ID:** 012201786-0024

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | 1.06 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:42 KB |

Client Sample Description 30 / DWS-2FL-211-SB14 / 211 **Collected:** 2/4/2022 6:42:00 AM **Lab ID:** 012201786-0025

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|---------------|-----------|--------|-----------|---------------------|-------------------------|
| METALS | | | | | |
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:47 KB |

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 31 / DWS-1FL-106-SB15 / 106 **Collected:** 2/4/2022 6:43:00 AM **Lab ID:** 012201786-0026

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:48 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 32 / DWS-2FL-212-SB16 / 212 **Collected:** 2/4/2022 6:44:00 AM **Lab ID:** 012201786-0027

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:50 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 33 / DWS-1FL-105-SB17 / 105 **Collected:** 2/4/2022 6:45:00 AM **Lab ID:** 012201786-0028

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:51 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 34 / DWS-2FL-213-SB18 / 213 **Collected:** 2/4/2022 6:47:00 AM **Lab ID:** 012201786-0029

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:53 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 35 / DWS-1FL-108-SB19 / 108 **Collected:** 2/4/2022 6:48:00 AM **Lab ID:** 012201786-0030

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 4.34 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:54 KB |
|-------|------|------|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012201786

CustomerID: TTIE54

CustomerPO: 034248

ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 36 / DWS-2FL-214-SB20 / 214 **Collected:** 2/4/2022 6:50:00 AM **Lab ID:** 012201786-0031

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:56 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 37 / DWS-1FL-107-SB21 / 107 **Collected:** 2/4/2022 6:50:00 AM **Lab ID:** 012201786-0032

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 05:57 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 38 / DWS-1FL-107-S29 / 107 **Collected:** 2/4/2022 6:52:00 AM **Lab ID:** 012201786-0033

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|------|-----------|-------------|-------------------|
| 200.8 | Lead | 1.61 | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:05 KB |
|-------|------|------|-----------|-------------|-------------------|

Client Sample Description 39 / DWS-2FL-215-SB22 / 215 **Collected:** 2/4/2022 6:55:00 AM **Lab ID:** 012201786-0034

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:07 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 40 / DWS-1FL-110-SB23 / 110 **Collected:** 2/4/2022 6:57:00 AM **Lab ID:** 012201786-0035

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:08 KB |
|-------|------|----|-----------|-------------|-------------------|

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012201786
 CustomerID: TTIE54
 CustomerPO: 034248
 ProjectID:

Attn: **Nathanael Roberts**
TTI Environmental Inc.
1253 North Church Street
Moorestown, NJ 08057

Phone: (856) 840-8800
 Fax: (856) 840-8815
 Received: 2/4/2022 11:40 AM

Project: 21-359 / Dawes Ave School

Analytical Results

Client Sample Description 41 / DWS-2FL-216A-SB24 / 216A **Collected:** 2/4/2022 6:59:00 AM **Lab ID:** 012201786-0036

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:10 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 42 / DWS-2FL-216B-SB25 / 216B **Collected:** 2/4/2022 7:02:00 AM **Lab ID:** 012201786-0037

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:11 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 43 / DWS-1FL-109-SB26 / 109 **Collected:** 2/4/2022 7:05:00 AM **Lab ID:** 012201786-0038

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:13 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description 44 / DWS-2FL-217-SB27 / 217 **Collected:** 2/4/2022 7:10:00 AM **Lab ID:** 012201786-0039

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:15 KB |
|-------|------|----|-----------|-------------|-------------------|

Client Sample Description Field Blank **Collected:** 2/4/2022 **Lab ID:** 012201786-0040

| Method | Parameter | Result | RL Units | Prep Date & Analyst | Analysis Date & Analyst |
|--------|-----------|--------|----------|---------------------|-------------------------|
|--------|-----------|--------|----------|---------------------|-------------------------|

METALS

| | | | | | |
|-------|------|----|-----------|-------------|-------------------|
| 200.8 | Lead | ND | 1.00 µg/L | 2/8/2022 KB | 2/9/2022 06:16 KB |
|-------|------|----|-----------|-------------|-------------------|

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results

| Field ID | Date Sampled | Concentration in ug/L |
|---|--------------|-----------------------|
| 1 / JRS-GYM-DW1 / Boys Gym | 2/2/2022 | 9.67 |
| 2 / JRS-GYM-DW2 / Girls Gym | 2/2/2022 | 2.22 |
| 11 / JRS-HWE-DW3 / Hallway East (Near 106) | 2/2/2022 | <1.00 |
| 12 / JRS-HWE-DW4 / Hallway East (Near 106) | 2/2/2022 | <1.00 |
| 13 / JRS-HWE-DW5 / Hallway East (Near 106) | 2/2/2022 | <1.00 |
| 14 / JRS-106-S3 / 106 | 2/2/2022 | 1.17 |
| 15 / JRS-112-S4 / HomeEc 112 | 2/2/2022 | 19.7 |
| 16 / JRS-112-S5 / HomeEc 112 | 2/2/2022 | 2.99 |
| 17 / JRS-112-S6 / HomeEc 112 | 2/2/2022 | 42.4 |
| 18 / JRS-112-S7 / HomeEc 112 | 2/2/2022 | 8.00 |
| 19 / JRS-112-S8 / HomeEc 112 | 2/2/2022 | 58.2 |
| 20 / JRS-122-S9 / 122 | 2/2/2022 | 5.84 |
| 21 / JRS-HWN-DW6 / Hallway North (Near 124A) | 2/2/2022 | <1.00 |
| 22 / JRS-HWN-DW7 / Hallway North (Near 124A) | 2/2/2022 | <1.00 |
| 23 / JRS-115-S10 / Teacher's Lounge | 2/2/2022 | 4.04 |
| 24 / JRS-HWS-DW8 / Hallway South (Near Gym) | 2/2/2022 | <1.00 |
| 25 / JRS-HWS-DW9 / Hallway South (Near Gym) | 2/2/2022 | <1.00 |
| 26 / JRS-HWS-DW10 / Hallway South (Near Gym) | 2/2/2022 | <1.00 |
| 27 / JRS-KIT-ICE1 / Kitchen | 2/2/2022 | 3.25 |
| 28 / JRS-KITS11 / Kitchen | 2/2/2022 | 2.05 |
| 29 / JRS-KITS12 / Kitchen | 2/2/2022 | <1.00 |
| 30 / JRS-KITS13 / Kitchen | 2/2/2022 | <1.00 |
| 31 / JRS-KITS14 / Kitchen | 2/2/2022 | <1.00 |
| 33 / JRS-NRS-S16 / Nurse | 2/2/2022 | 10.5 |
| 35 / JRS-HWW-DW11 / Hallway West | 2/2/2022 | <1.00 |
| 37 / JRS-120-SB1 / 129 | 2/2/2022 | 11.5 |
| 38A / JRS-WKRM-ORS / Room 117 Faculty Work Room | 2/2/2022 | 48.7 |
| 39 / JRS-PHW-DW12 / Prim Hall West | 2/2/2022 | 2.74 |
| 40 / JRS-PHW-DW13 / Prim Hall West | 2/2/2022 | <1.00 |
| 42 / JRS-209-SB2 / 209 | 2/2/2022 | 4.18 |
| 44 / JRS-211-SB3 / 211 | 2/2/2022 | 2.04 |
| 46 / JRS-212-SB4 / 212 | 2/2/2022 | 5.09 |
| 48 / JRS-205-SB5 / 205 | 2/2/2022 | 5.87 |
| 50 / JRS-244-SB6 / 244 Faculty Lounge | 2/2/2022 | 20.8 |
| 52 / JRS-204-SB7 / 204 | 2/2/2022 | 6.24 |
| 54 / JRS-203-SB8 / 203 | 2/2/2022 | 1.23 |
| 56 / JRS-201-SB9 / 201 | 2/2/2022 | 3.45 |
| 58 / JRS-202-SB10 / 202 | 2/2/2022 | 1.30 |
| 60 / JRS-200-SB11 / 200 | 2/2/2022 | 4.03 |
| 24B / JRS-HWS-DW8-BF / Hallway South (Near Gym) | 2/2/2022 | <1.00 |
| 11B / JRS-HWE-DW3-BF / Hallway East (Near 106) | 2/2/2022 | <1.00 |
| 21B / JRS-HWN-DW68-BF / Hallway North (Near 124A) | 2/2/2022 | <1.00 |
| 35B / JRS-HWW-DW11-BF / Hallway West (Near Nurse) | 2/2/2022 | <1.00 |
| 40B / JRS-PHW-DW13-BF / Prim Hall West | 2/2/2022 | <1.00 |

| Field ID | Date Sampled | Concentration in ug/L |
|-----------------------------------|--------------|-----------------------|
| 1 / NYA-GF-DW1 / Ground Floor | 2/2/2022 | <1.00 |
| 2 / NYA-GF-DW2 / Ground Floor | 2/2/2022 | <1.00 |
| 8 / NYA-FF-DW3 / 1st Floor | 2/2/2022 | <1.00 |
| 9 / NYA-FF-SLS / 1st Floor | 2/2/2022 | 3.34 |
| 10 / NYA-FF-NRS / 1st Floor | 2/2/2022 | 13.5 |
| 11 / NYA-SF-DW4 / 2nd Floor | 2/2/2022 | 2.42 |
| 2B / NYA-GF-DW2-BF / Ground Floor | 2/2/2022 | <1.00 |
| 8B / NYA-FF-DW3-BF / 1st Floor | 2/2/2022 | <1.00 |
| 12 / Field Blank | 2/2/2022 | <1.00 |

| Field ID | Date Sampled | Concentration in ug/L |
|---|--------------|-----------------------|
| 1 / DWS-1FL-GYM-DW1 / Gym, Right | 2/4/2022 | <1.00 |
| 3 / DWS-1FL-KIT-S1 / Kitchen | 2/4/2022 | 3.26 |
| 4 / DWS-1FL-KIT-S2 / Kitchen Small | 2/4/2022 | 2.60 |
| 5 / DWS-1FL-KIT-S3 / Kitchen Deep | 2/4/2022 | 3.29 |
| 6 / DWS-1FL-PEO-S4 / PE Office | 2/4/2022 | 3.53 |
| 7 / DWS-1FL-NRS-S5 / Nurse's Office | 2/4/2022 | 1.88 |
| 8 / DWS-1FL-WRK-S6 / Faculty Work Room | 2/4/2022 | 15.3 |
| 9 / DWS-1FL-MOB-DW3 / Main Office | 2/4/2022 | <1.00 |
| 10 / DWS-1FL-LIB-S7 / Workroom-Library-100A | 2/4/2022 | <1.00 |
| 11 / DWS-2FL-203-SB1 / 203 | 2/4/2022 | 4.08 |
| 12 / DWS-2FL-204-SB2 / 204 | 2/4/2022 | <1.00 |
| 13 / DWS-2FL-205A-SB3 / 205A | 2/4/2022 | 1.88 |
| 14 / DWS-2FL-206-SB4 / 206 | 2/4/2022 | <1.00 |
| 15 / DWS-2FL-205B-SB5 / 205B | 2/4/2022 | 1.55 |
| 16 / DWS-2FL-207-SB6 / 207 | 2/4/2022 | <1.00 |
| 17 / DWS-2FL-208-SB7 / 208 | 2/4/2022 | <1.00 |
| 18 / DWS-1FL-101-SB8 / 101 | 2/4/2022 | <1.00 |
| 21 / DWS-1FL-HW-DW6 / 1st Floor Hall Right | 2/4/2022 | <1.00 |
| 23 / DWS-2FL-HW-DW8 / 2nd Floor Hall Center | 2/4/2022 | <1.00 |
| 25 / DWS-1FL-103-SB9 / 103 | 2/4/2022 | <1.00 |
| 26 / DWS-2FL-210-SB10 / 210 | 2/4/2022 | <1.00 |
| 27 / DWS-1FL-102-SB11 / 102 | 2/4/2022 | <1.00 |
| 28 / DWS-2FL-209-SB12 / 209 | 2/4/2022 | <1.00 |
| 29 / DWS-1FL-104-SB13 / 104 | 2/4/2022 | 1.06 |
| 30 / DWS-2FL-211-SB14 / 211 | 2/4/2022 | <1.00 |
| 31 / DWS-1FL-106-SB15 / 106 | 2/4/2022 | <1.00 |
| 32 / DWS-2FL-212-SB16 / 212 | 2/4/2022 | <1.00 |
| 33 / DWS-1FL-105-SB17 / 105 | 2/4/2022 | <1.00 |
| 34 / DWS-2FL-213-SB18 / 213 | 2/4/2022 | <1.00 |
| 35 / DWS-1FL-108-SB19 / 108 | 2/4/2022 | 4.34 |
| 36 / DWS-2FL-214-SB20 / 214 | 2/4/2022 | <1.00 |
| 37 / DWS-1FL-107-SB21 / 107 | 2/4/2022 | <1.00 |
| 38 / DWS-1FL-107-S29 / 107 | 2/4/2022 | 1.61 |
| 39 / DWS-2FL-215-SB22 / 215 | 2/4/2022 | <1.00 |
| 40 / DWS-1FL-110-SB23 / 110 | 2/4/2022 | <1.00 |
| 41 / DWS-2FL-216A-SB24 / 216A | 2/4/2022 | <1.00 |
| 42 / DWS-2FL-216B-SB25 / 216B | 2/4/2022 | <1.00 |
| 43 / DWS-1FL-109-SB26 / 109 | 2/4/2022 | <1.00 |
| 44 / DWS-2FL-217-SB27 / 217 | 2/4/2022 | <1.00 |
| Field Blank | 2/4/2022 | <1.00 |